

HYPower Hydraulic Power Supply Unit

University of Saskatchewan - Mechanical Engineering – Fluid Power and Controls

**Hydraulic Power Supply (HYPower Unit, Room 1B19.1) with Test Bench
Unit (West Wall, Room 1B19)**

Effective Date: May 31, 2010

Last Revised: May 31, 2010

Developed By: Doug. Bitner.

Approved By:

Primary Contact: Doug Bitner

Rm: 1B15.1

966-5462

Secondary Contact:

HYPower Hydraulic Power Supply Unit
University of Saskatchewan - Mechanical Engineering – Fluid Power and Controls

Table of Contents

SECTION	SECTION TITLE	PAGE
1.	Purpose and Scope.....	3
2.	Responsibilities and Prequalifications	3
3.	Equipment and Consumables Required	3
4.	Definitions and Abbreviations	3
5.	Hazards.....	4
5.1.	Physical.....	4
5.2.	Chemical and Toxicological	4
6.	Chemical Spill/Release & Emergency Response Procedures.....	4
7.	Waste Disposal Procedures	4
8.	Procedural Steps	5
9.	References	6
10.	Signatures of Understanding	7

HYPower Hydraulic Power Supply Unit

University of Saskatchewan - Mechanical Engineering – Fluid Power and Controls

1. PURPOSE AND SCOPE

This SOP provides general instructions to operate the HYPower hydraulic power supply and test bench unit. All general lab safety practices must be followed in addition to those cited in this SOP. This SOP applies to all parties using this equipment.

2. RESPONSIBILITIES AND PREQUALIFICATIONS

All workers must:

- Have completed the WESP Lab Safety Course and received a certificate.
- Received training from the Departmental Assistant in charge of the laboratory area.
- Read and understand this SOP prior to beginning the procedure.
- Signed the signatures of understanding page to verify they have read and understood this SOP and any relevant MSDS.
- Have read and understood the University of Saskatchewan **Laboratory Safety Manual**, which can be found with the MSDS binders in rooms 2C26 and OC17.
- This procedure is not to be started outside of regular business hours (unless special permission is given by the Departmental Assistant in charge of the laboratory space) and **MUST NOT** be conducted while working **ALONE**.

3. EQUIPMENT AND CONSUMABLES REQUIRED

The following Personal Protective Equipment (PPE) is required for this procedure:

- Closed toed shoes and long pants
- Safety glasses, goggles or Face Shield
- This SOP

4. DEFINITIONS AND ABBREVIATIONS

None applicable

HYPower Hydraulic Power Supply Unit

University of Saskatchewan - Mechanical Engineering – Fluid Power and Controls

5. HAZARDS

5.1. Physical

- **THE HYDRAULIC POWER SUPPLY CANNOT BE LEFT UNATTENDED WHILE BEING OPERATED.**
- Slip hazard from oil spills or oil leaks on the floor. Clean up immediately
- Cut hazard due to pressurized oil jets from leaking pipes or hoses.
- Burn hazard due to hot pipes, hoses, valves or actuators. Avoid contact

5.2. Chemical and Toxicological

- Toxic hazard if oil jet penetrates the skin.

6. CHEMICAL SPILL/RELEASE & EMERGENCY RESPONSE PROCEDURES

Emergency Contact Information:

FIRE Pull an alarm station AND call 9-911 (just 911 from pay phone or cell)

CAMPUS SECURITY 966-5555 24 hours a day

AMBULANCE 9-911 (just 911 from pay phone or cell)

CHEMICAL SPILLS 966-8497 or 966-8493 (days)
966-5555 (evenings and weekends)

7. WASTE DISPOSAL PROCEDURES

All waste oil must be placed in drain pans for recycling.

HYPower Hydraulic Power Supply Unit

University of Saskatchewan - Mechanical Engineering – Fluid Power and Controls

8. PROCEDURAL STEPS

Stage 1: Setting Up

1. Ensure that all lines are properly connected and unused ports are capped, plugged or closed
2. Ensure that all valves are closed and pressure control valve knobs are locked
3. Position the Emergency Off Switch (Red button) where it is easily accessible in case of emergency
4. Ensure level of fluid in the reservoir is adequate (check sight glass to ensure oil is above minimum level)

Stage 2: Start Up Procedure

5. Press Green button to start up the pump
6. Turn on the swash-plate power supply switch
7. Slowly advance the swash-plate lever in direction shown
8. Open the Supply valves (top one first, bottom one second)
9. Release the lock nut on the pressure control valve and slowly increase the system as required by the test
10. The system should now be up and running

Caution: * Do Not Exceed 60 C operating temperature
 * Do Not Exceed 3000 psi pressure

Stage 3: Shut Down Procedure

11. Release system pressure to minimum level and lock pressure control valve using lock
12. Close both supply valves (top one first, bottom one second)
13. Return the swash-plate lever to its middle position
14. Stop Pump (press Red button)

HYPower Hydraulic Power Supply Unit

University of Saskatchewan - Mechanical Engineering – Fluid Power and Controls

9. REFERENCES

University of Saskatchewan WSEP Documents:

Laboratory Safety Manual:

http://www.usask.ca/dhse/file_view/download.php/Laboratory_Safety_Manual.pdf?id=32&view=1

HYPower Hydraulic Power Supply Unit

University of Saskatchewan - Mechanical Engineering – Fluid Power and Controls

10. SIGNATURES OF UNDERSTANDING

By signing this form I acknowledge that I have read and understand this SOP, as well as the applicable MSDS's and that I will conduct myself in accordance with this SOP and the general laboratory rules.

NOTE: ALL SIGNATURES MUST BE PRESENT ON THE SOP LOCATED IN ROOM 1B19, other SOP's are made available for convenience only.

Name (Print)	Signature