

# Job Safety Analysis

## (JSA)

College/Department/Unit:

Title of Job Activity: Lifting devices, ladders, scaffolds

Title of worker who does activity:

Supervisor of Activity:

Competency Requirements: Certified to operator JLG or spider lift or bucket truck or scissor lift

Monitoring and Measurement:

Date of Original JSA:

JSA #:

JSA Approved by: \_\_\_\_\_ Date: \_\_\_\_\_

Review Frequency:

Review History

Review Date	Reviewed By	Signature

Individual worker sign off for reading and understanding the Job Safety Analysis:

Date	Signature

Basic Job Steps	Possible Hazards	Preventative Measures
Using lifts, JLG, spider lift, bucket truck, scissor lift	Personal injury Injury to other Damaged equipment	All operators of this equipment must be certified and on operation list
Ladders and step ladders	Damaged ladder Falls, injury	Visual inspections prior to use, Never use a painted wooden ladder, the paint may hide cracks and damage Never step on the top rung or platform, get a bigger ladder if needed
Ladders, extension ladder	Falls, injury	Set ladder at proper working ratio 4 to 1, visual inspection for damage Aware of surroundings, good footing, over head hazards, weather conditions, level ground  Maintain 3 points of contact when going up or down ladder  Have someone attend the ladder, tie off ladder if not one able to attend ladder
Scaffolds	Uncertified scaffold	Verify that scaffold has been certified for use, check for certification tag
Baker Scaffold	Falls	Ensure platform is not on the top rung and that side rails are in place Lock wheels in place